

Inspection Checklist:

Section 8. Barriers

- Detectable Leading Edge
- Full Perimeter of Dining Area; Exception of Access Openings
- Fencing
 - Height: At Least 36"
 - "Open" Appearance: Height of between 36" and 50"; 50% Transparency
 - Maximum Distance from Ground: Detectable for Visually Impaired
- Access Width; Minimum 48"
 - Access Width: _____ ft/in

Section 9. Planters

- Planter Height: Maximum of 36" Above Level of the Sidewalk
- Plant Height: Maximum of 108" Above Level of the Sidewalk
- Planter Material; Metal or Wood

Section 10. Furniture and Fixtures

- Tables & Chairs; White Resin Tables and Chairs are Prohibited
- Umbrellas;
 - Bottom Edge at Least 7 Feet or 84" from the Sidewalk Surface
 - Max Height: 10 Feet from Sidewalk Surface
 - Must be Contained w/in Outdoor Dining Area
- Lighting; Must be Contained in Outdoor Dining Area

Section 11. Circulation Room

- Defined path of 60" (5 Ft.) Minimum Width from Pedestrian Barrier to the Curb Edge
 - City-Owned Permanent Fixtures may result in a narrowing of pedestrian route to a minimum of 32" wide for a distance of more than 48"
- Restaurant Measurements:
 - Sidewalk: _____ ft/in
 - Tree: _____ ft/in
 - Light Post: _____ ft/in
 - Bench: _____ ft/in
 - Bike Rack: _____ ft/in

Section 12. Signage

- Signage Must be Contained w/in Outdoor Dining Area
- No signage and/or advertising is allowed on the umbrellas

Section 13. Setback from Other Businesses

- Outdoor dining area shall not exceed the width and side to side position of the space occupied by the operating dining establishment